

Forta Pro Bathroom POD

Holder/Issued to

Forta Prefab Ltd.

Melgaila Street 1a, LV-1050 Riga, Latvia
Organisation number/VAT number: 40 103 727 283
Phone: +371 67 32 32 34
E-mail: info@fortapro.com, Web: www.fortapro.com

Product description

Prefabricated bathroom unit

Intended use

Prefabricated bathroom unit for use as bathrooms in homes, hotels and other buildings with corresponding requirements.

Approval

The product satisfies the requirements set forth in chapter 8, 4 § 3 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR)

BBR

Material	6:11
Moisture, General	6:51
Watertight layers	6:5331
Underlayment's for watertight layers	6:5333
Concealed surfaces in rooms or building components	6:5334
The diversion of water to a floor drain	6:5335

Associated documents

Installation and maintenance manual for Forta Pro Bathroom POD

Control

The factory production control (FPC) is monitored by an independent inspection body.
Control agreement: 210-19-0177, Inspection body: RISE Research Institutes of Sweden AB

When the building proprietor performs inspection at the building site /When inspection before use is performed, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval and associated documents. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this approval is based.

Type approval SC0268-19 | 2020-02-05

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sweden
Phone: +46 10-516 50 00
certifiering@ri.se | www.ri.se

2019-06-10



9P05231



Accred. no. 1002
Certification of
Products
ISO/IEC 17065

Manufacturing place

Production control includes the following place:
Forta Prefab Ltd., Tukums, Latvia

Marking

The product to be marked at the factory. The marking consists of a sign/label/text on every product/packing supplied and includes:

Holder/Distributor	Forta Prefab Ltd
Product type designation	Forta Pro Bathroom POD
Consecutive manufacture no./date of production	nr/date
Type approval number	SC0268-19
Boverket's registered trademark	✚
RISE Accreditation number	1002
Certification body and Inspection body	RISE Research Institutes of Sweden AB

Basis for assessment/approval

Product description, dated 2019-08-12
Drawing, dated 2018-12-09 and 2019-03-06
ETA for Mapeguard WP90 and Mapeguard WP200, ETA 15/0257 dated 2016-12-05
SINTEF Prøverapport TG20694 2019:00936 ETAG 022 annex A and E, dated 2020-01-10
Swedish type approval for used: Floor drain, Water mixer, WC and Washbasin
Test reports for corrosion test dated 2013-06-28, 2013-08-20, and 2016-03-15 from Richter System
Structural analysis, dated 2020-01-28 from Forta Pro

Validity

Valid through 2025-02-04.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.

Johan Åkesson